

Article

A Multi-Energy System Expansion Planning Method Using a Linearized Load-Energy Curve: A Case Study in South Korea

Woong Ko ¹, Jong-Keun Park ¹, Mun-Kyeom Kim ^{2,*} and Jae-Haeng Heo ³

¹ School of Electrical Engineering & Computer Science, Seoul National University, Gwanak-ro 1, Gwanak-gu, Seoul 08826, Korea; kwoong@snu.ac.kr (W.K.); parkjk@snu.ac.kr (J.-K.P.)

² Department of Energy System Engineering, Chung-Ang University, 84 Heukseok-ro, Dongjak-gu, Seoul 06974, Korea

³ Research and Development Laboratory, Raonfreinds, 23, 16 Cheomdanbencheo-ro, Buk-gu, Gwangju 61009, Korea; jhheo78@gmail.com

* Correspondence: mkim@cau.ac.kr; Tel.: +82-2-5271-5867

Received: 9 September 2017; Accepted: 16 October 2017; Published: 20 October 2017

Abstract: Multi-energy systems can integrate heat and electrical energy efficiently, using resources such as cogeneration. In order to meet energy demand cost-effectively in a multi-energy system, adopting appropriate energy resources at the right time is of great importance. In this paper, we propose an expansion planning method for a multi-energy system that supplies heat and electrical energy. The proposed approach formulates expansion planning as a mixed integer linear programming (MILP) problem. The objective is to minimize the sum of the annualized cost of the multi-energy system. The candidate resources that constitute the cost of the multi-energy system are fuel-based power generators, heat-only boilers, a combined heat and power (CHP) unit, energy storage resources, and a renewable electrical power source. We use a load-energy curve, instead of a load-duration curve, for constructing the optimization model, which is subsequently linearized using a Douglas-Peucker algorithm. The residual load-energy curve, for utilizing the renewable electrical power source, is also linearized. This study demonstrates the effectiveness of the proposed method through a comparison with a conventional linearization method. In addition, we evaluate the cost and planning schedules of different case studies, according to the configuration of resources in the multi-energy system.

Keywords: multi-energy system; mixed integer linear programming; energy expansion planning; combined heat and power; renewable electrical power source

1. Introduction

With the increased emphasis on energy efficiency under current environmental policy, there has been growing interest in systems that can efficiently supply and consume energy. In the operation and planning of conventional energy systems, single energy sources are typically considered individually, though these sources have interdependencies [1]. In addition, as a result of economic and environmental concerns, energy systems tend to operate in a decentralized manner. Recently, the multi-energy system concept has been introduced [2]. In a multi-energy system, electricity, heat, and gas sources are treated interdependently. The cost of fuel and the availability of power from a gas turbine power plant depend on the price of gas and the status of the gas supply facility, respectively [3]. It has been noted that combined heat and power (CHP) systems could afford significant energy efficiency by producing heat and electricity from a single fuel, including natural gas [4]. In urban regions where various energy sources, including district heat, electricity, and natural gas, are consumed, CHP systems can improve the environmental performances. For example, these systems can avoid

the use of methane hydrate by providing other resources with heat for preheating of natural gas [5,6]. In addition, thermal energy storage decouples the supply of electrical energy from that of heat energy when a cogeneration unit is used, thereby improving the efficiency of energy supply [7]. To efficiently use these facilities in multi-energy systems, it is necessary to make a plan for each energy sector.

Many studies have investigated the integrated operation and planning of gas and electricity supplies. From the perspective of system operation, generator commitment was determined on the basis of the status of gas pipes [3]. In contrast, in the integrated energy expansion planning process detailed in [8,9], the construction of generators, gas wells, gas pipes, and gas tanks was also considered to meet the gas demand, including the demand for gas as a fuel for generators. Integrated operation and planning of heat and electricity have also been studied. The optimal operating conditions required for heat-only boilers, fuel-based generators, and CHP units to meet heat and electricity demand, were determined [10]. Expansion planning of CHP units was also considered in terms of the amount of heat and electricity consumed [11]. The model in [12] was proposed to design an energy integrated multi-microgrid system that could provide microgrid operation and heating pipelines to meet heat and electricity demand. There have also been studies on energy hubs that can integrate multiple forms of energy such as, gas, heat, and electricity [13]. The method discussed in [14] was used to design an energy hub comprising CHP units and other thermal and electrical resources considering reliability constraints. In contrast, an optimal operation strategy in multiple energy hub systems considered the efficiency of energy conversion and the price of electricity [15]. Furthermore, a model called an energy internet in [16] was based on the energy hub and was proposed to consider dynamic operation of multiple energy flows. Although it is desirable to consider all forms of energy in the operation and planning of an energy system, the focus is predominantly on heat and electrical energy, as gas is converted into these forms of energy.

Expansion planning models for heat and electrical systems have been designed to minimize the investment and operation cost of energy resources. In [17], the integrated expansion planning method was applied in a case study on the Alberta region (Canada), where many CHP units might be used. Furthermore, other models detailed in [18,19] were designed to minimize energy loss and voltage fluctuation, as well as cost. The study in [20] proposed an expansion planning model for distributed multi-energy generation to cope with long-term uncertainty, including operation and investment flexibility. A notable feature of the expansion planning method proposed in [21] was the consideration of CHP units and boilers in a district energy system to provide heat and electricity. Expansion planning methods were also proposed in [14,22] to determine the requisite size of energy hub facilities, including CHP units, boilers, and energy storage resources. However, these methods rarely consider resources other than those detailed above. It is necessary to consider a variety of energy resources in expansion planning, as energy systems can potentially adopt a wider range of resources than those listed.

The expansion planning problem can be modeled as a mixed integer linear programming (MILP) problem, which can be formulated by linearizing the constraints. Linearization is realized by selecting typical days in project years instead of using an entire year of demand data [14,20,22], or by using a stepwise representation of a load duration curve (LDC) [23]. Although it is better to linearize the curve as closely as possible to the original data, the computational burden increases with the number of linearization segments [24]. Linearization is important in the MILP problem; however, there is no consistent standard for how to select typical days or how to construct a stepwise function.

This paper proposes a method to model an expansion planning problem for a multi-energy system where energy resources supply the heat and electricity demand. Furthermore, in this model, we focus on the method of planning energy resources on an annual basis rather than an hourly basis, because we suggest a method of designing rather than operating a multi-energy system. Therefore, this paper will cover the following:

- The expansion planning problem for a multi-energy system, where considering various energy resources, including fuel-based generators and a renewable electrical power source, as well as a CHP unit and energy storage resources, is modeled as an MILP problem with linearized constraints.

- To model linearized constraints including a linearized load curve, we use a load-energy curve instead of the LDC, and apply a Douglas-Peucker algorithm that can approximate linear functions and minimize the distortion of the original demand function.
- To validate the use of a linearized load-energy curve, the results of optimization methods using the linearized load-energy curve and the stepwise representation of LDC are compared.
- A case study for a multi-energy system based on a benchmark case from Goyang city in South Korea is presented.

The rest of this paper is organized as follows: Section 2 presents the multi-energy system considered in this paper. An objective function and basic models of the resources are described in Section 3; In Section 4, we introduce the load-energy curve, which is used instead of a load-duration curve in the expansion planning problem, and linearization using the Douglas-Peucker algorithm; The optimization process and a comparison of the proposed optimization method with a conventional method are shown in Section 5; The proposed method is illustrated with several case studies, in Section 6; The conclusions of this paper are presented in Section 7.

2. Multi-Energy System Overview

Multi-energy systems have been modeled in various forms. The distributed multi-energy generation system in [20] and the energy hub model in [25] were composed of heat and electricity networks, including CHP units, boilers, and storage resources. Based on the configuration of these models, the multi-energy system model in this work also consists of a heat and an electricity network. In addition, to utilize various energy resources except CHP units, boilers, and storage resources included in conventional models, this model is assumed to represent a self-sufficient system, and this system is then modeled as shown in Figure 1. This model is composed of the heat and electricity network, identified using dashed lines and solid lines, respectively. In this work, the energy generation resources for supplying heat or electricity are assumed to be unidirectional components. A renewable energy source is also considered, particularly with respect to electricity generation, because this resource is expected to be widely used to reduce the primary energy consumption, as shown in [26]. Furthermore, in [27], the excess electricity due to generation of this resource could be converted to heat. Although utilization of this resource can involve various energy transitions and conversions, this resource is assumed to produce only electricity, because our model cannot yet consider fuel usage or energy transitions caused by other resources except the CHP unit. We note that the CHP unit, identified using the dash-dotted line, can generate thermal and electrical energy simultaneously. In addition, because the energy storage resources can charge or discharge energy, they are configured as bidirectional components.




Figure 1. Model of the multi-energy system.

3. Basic Optimization Model

This section introduces the objective function and the basic resource model for a multi-energy system expansion planning problem modeled using MILP.

3.1. Objective Function

The objective of the multi-energy system expansion planning problem is to define the optimum energy generation mix, and to minimize the sum of the annualized costs, including the initial investment and operation costs of all energy resources, over the planning horizon, N_Y . The objective function is modelled as:

$$\text{Minimize } \sum_{y=1}^{N_Y} \left(\text{COST}_e^y + \text{COST}_h^y + \text{COST}_{\text{CHP}}^y \right) \quad (1)$$

where, COST_e^y , COST_h^y , and $\text{COST}_{\text{CHP}}^y$ are the respective sums of the annualized investment and the operational costs for electrical energy, heat energy, and the CHP unit for the planning year, y . Each cost consists of a fixed component, including capital and fixed operation and maintenance costs relating to the capacity of a resource, and a variable component, including fuel costs and variable operation and maintenance costs relating to the utilized energy of a resource, and is defined as below:

$$\begin{aligned} \text{COST}_e^y = & \sum_{i=1}^{N_{ER}} \left(1 - \rho_{\text{CHP},e}^i \right) \cdot (1 + \gamma_d)^{-y} \cdot \left(\text{CRF}_e^i \cdot \text{CC}_e^i + \text{FOMC}_e^i \right) \cdot \left[\sum_{c=1}^{N_C} C_e^{i,c} \cdot v_e^{i,c,y} \right] \\ & + \sum_{i=1}^{N_{ER}} \left(1 - \rho_{\text{CHP},e}^i \right) \cdot (1 + \gamma_d)^{-y} \cdot \left(\text{FC}_e^i + \text{VOMC}_e^i \right) \cdot \left[\sum_{si=1}^{N_{EST}} E_e^{i,si,y} \right] \quad \forall y \end{aligned} \quad (2)$$

$$\begin{aligned} \text{COST}_h^y = & \sum_{j=1}^{N_{HR}} \left(1 - \rho_{\text{CHP},h}^j \right) \cdot (1 + \gamma_d)^{-y} \cdot \left(\text{CRF}_h^j \cdot \text{CC}_h^j + \text{FOMC}_h^j \right) \cdot \left[\sum_{c=1}^{N_C} C_h^{j,c} \cdot v_h^{j,c,y} \right] \\ & + \sum_{j=1}^{N_{HR}} \left(1 - \rho_{\text{CHP},h}^j \right) \cdot (1 + \gamma_d)^{-y} \cdot \left(\text{FC}_h^j + \text{VOMC}_h^j \right) \cdot \left[\sum_{sj=1}^{N_{HST}} E_h^{j,sj,y} \right] \quad \forall y \end{aligned} \quad (3)$$

$$\begin{aligned} \text{COST}_{\text{CHP}}^y = & \sum_{i=1}^{N_{ER}} \rho_{\text{CHP},e}^i \cdot (1 + \gamma_d)^{-y} \cdot \left(\text{CRF}_e^i \cdot \text{CC}_e^i + \text{FOMC}_e^i \right) \cdot \left[\sum_{c=1}^{N_C} C_e^{i,c} \cdot v_e^{i,c,y} \right] \\ & + \sum_{i=1}^{N_{ER}} \rho_{\text{CHP},e}^i \cdot (1 + \gamma_d)^{-y} \cdot \left(\text{FC}_e^i + \text{VOMC}_e^i \right) \cdot \left[\sum_{si=1}^{N_{EST}} E_e^{i,si,y} \right] \quad \forall y \end{aligned} \quad (4)$$

where:

$$\text{CRF}_e^i = \frac{\gamma_d(1+\gamma_d)^{LT_e^i}}{(1+\gamma_d)^{LT_e^i}-1}, \text{CRF}_h^j = \frac{\gamma_d(1+\gamma_d)^{LT_h^j}}{(1+\gamma_d)^{LT_h^j}-1} \quad \forall i, \forall j. \quad (5)$$

Equations (2)–(4) show the total cost of resources, including fixed costs and variable costs. Fixed costs consist of the candidate capacity of the electrical and heat energy resources, $C_e^{i,c}$, $C_h^{j,c}$, the overnight capital costs, CC_e^i , CC_h^j , the capital recovery factor defined in Equation (5), CRF_e^i , CRF_h^j , and the fixed operation and maintenance costs, FOMC_e^i , FOMC_h^j . In the same way, the variable costs for the planning year consist of the utilized energy, $E_e^{i,si,y}$, $E_h^{j,sj,y}$, the cost of fuel, FC_e^i , FC_h^j , and the variable operation and maintenance cost, VOMC_e^i , VOMC_h^j . Besides, in modeling fixed costs and variable costs for the planning year, we apply the interest rate, γ_d .

As the CHP unit is capable of generating heat and electricity simultaneously, it can be classified either as a heat generation resource or an electricity generation. Hence, the cost of the CHP unit should be calculated separately, because the objective function contains the cost of the heat generation resources and the electricity generation resources. As shown in Equations (2) and (3), the contribution of the CHP unit to the total cost of the heat generation and electricity generation resources can be split, by introducing an index for the CHP unit, $\rho_{\text{CHP},e}^i$, $\rho_{\text{CHP},h}^j$. Therefore, the total cost of the CHP unit can be calculated using Equation (4).

3.2. CHP Constraints

The allocation of resources for heat and electricity is influenced by the CHP unit, as this resource can generate heat and electricity simultaneously. The heat-to-power ratio, α_{HPR} , determines the proportion of the heat and electricity output supplied by the CHP unit. Although it would vary with the heat and electricity output in hourly operation, it is assumed to have a constant value when the expected heat and electricity output of the CHP unit during a project year is considered, because the expansion planning problem in this work is not designed to consider hourly operation of the multi-energy system. It governs the amount of heat and electrical energy contributed to the desired capacity and the utilized energy, as shown in Equations (6) and (7):

$$\sum_{i=1}^{N_{ER}} \left(\rho_{CHP,e}^i \cdot \alpha_{HPR} \cdot \left[\sum_{si=1}^{N_{EST}} P_e^{i,si,y} \right] \right) = \sum_{j=1}^{N_{HR}} \left(\rho_{CHP,h}^j \cdot \left[\sum_{sj=1}^{N_{HST}} P_h^{j,sj,y} \right] \right) \quad \forall y \quad (6)$$

$$\sum_{i=1}^{N_{ER}} \left(\rho_{CHP,e}^i \cdot \alpha_{HPR} \cdot \left[\sum_{si=1}^{N_{EST}} E_e^{i,si,y} \right] \right) = \sum_{j=1}^{N_{HR}} \left(\rho_{CHP,h}^j \cdot \left[\sum_{sj=1}^{N_{HST}} E_h^{j,sj,y} \right] \right) \quad \forall y. \quad (7)$$

3.3. Energy Storage Constraints

Although energy storage resources in this system are similar to other resources from the perspective of estimating the utilized energy, they are charged from other resources, to discharge energy. Because the stored energy is designed to be completely discharged during the project year, the charging energy must be equal to the discharging energy, as in the definition below:

$$\sum_{i=1}^{N_{ER}} \left(\rho_{EES}^i \cdot \left[\sum_{si=1}^{N_{EST}} E_e^{i,si,y} \right] \right) = \sum_{i=1}^{N_{EST}} e_{EES}^{si,y}, \sum_{j=1}^{N_{HR}} \left(\rho_{TES}^j \cdot \left[\sum_{sj=1}^{N_{HST}} E_h^{j,sj,y} \right] \right) = \sum_{j=1}^{N_{HST}} e_{TES}^{sj,y} \quad \forall y. \quad (8)$$

In addition, since unlike other resources, the energy storage resources do not generate the energy required for charging, the range of charging energy can be defined as:

$$0 \leq e_{EES}^{si,y} \leq \sum_{i=1}^{N_{ER}} \left((1 - \rho_{EES}^i) \cdot E_e^{i,si,y} \right), 0 \leq e_{TES}^{sj,y} \leq \sum_{j=1}^{N_{HR}} \left((1 - \rho_{TES}^j) \cdot E_h^{j,sj,y} \right) \quad \forall si, \forall sj, \forall y. \quad (9)$$

3.4. Lifespan Constraints

The resource scheduled to be installed is designed to run continuously during its life span, and retired if it reaches the end of its life. In mathematical expression, the allocated candidate unit should operate for at least its lifetime, as follows:

$$\begin{aligned} \sum_{t=y}^{\text{Min}(N_Y, y+LT_e^i-1)} v_e^{i,c,t} &\geq LT_e^i \cdot \left(v_e^{i,c,y} - v_e^{i,c,y-1} \right) \quad \forall i, \forall c, \forall y, \quad (v_e^{i,c,0} = 0), \\ \sum_{t=y}^{\text{Min}(N_Y, y+LT_h^j-1)} v_h^{j,c,t} &\geq LT_h^j \cdot \left(v_h^{j,c,y} - v_h^{j,c,y-1} \right) \quad \forall j, \forall c, \forall y, \quad (v_h^{j,c,0} = 0). \end{aligned} \quad (10)$$

In contrast with deciding the operating period of an allocated candidate unit individually, the year of retirement for the allocated candidate unit is determined by comparing its life span with the cumulative operating year, as below:

$$\sum_{t=\text{Max}(1, y-LT_e^i)}^{\text{Max}(1, y)} v_e^{i,c,t} \leq LT_e^i, \quad \sum_{t=\text{Max}(1, y-LT_h^j)}^{\text{Max}(1, y)} v_h^{j,c,t} \leq LT_h^j \quad \forall i, \forall c, \forall y. \quad (11)$$

4. Linearized Load-Energy Curve

In this work, expansion planning is formulated as an MILP problem. For accurate modeling, because the amount of load demand and that of energy demand are used to determine the installed capacity and the utilized energy of candidate resources, respectively, it is important that these values can be extracted precisely from a load curve. The load curve must also be modeled considering the renewable electrical power source, which is treated as a negative load.

4.1. Load-Energy Curve and Linearization

Figure 2 shows the LDC known to be useful to formulate the expansion planning problem. This curve represents the amount of time that the available capacity of the energy resources exceeds a given load demand. The load values are arranged in descending order, and energy is obtained by integrating the load with respect to time, as shown in Figure 2. This method of calculating the energy makes expansion planning a non-linear programming problem. For this reason, a step-wise representation of the LDC was used to formulate the MILP problem in [28,29]. Although these stepwise curves might appear to be similar, the approximation methods for modeling them were not consistent; in these methods, the number of steps and the step size for minimizing the approximation error were estimated randomly.




Figure 2. Illustrative LDC.

In order to avoid the problem mentioned above, we use a load-energy curve, which illustrates the relationship between load and energy, instead of the LDC. An illustrative load-energy curve is depicted in Figure 3. The load of this curve is equal to that of the LDC, while the energy is calculated by the integral of the load with respect to the corresponding utilization time in the LDC. Contrary to determining the energy in the LDC, it can be seen from Figure 3 that the energy can be determined according to the load, without an integration process. This feature can be used for direct assignment of the utilized energy in the optimization problem.




Figure 3. Illustrative load-energy curve.

To appropriately model the MILP problem, the load-energy curve should be linearized. In this work, we apply the Douglas-Peucker algorithm to approximate this curve. This algorithm is used to

reduce the number of points in a curve, which is defined as a series of points [30]. Moreover, it has been noted that applying this algorithm to the approximation of functions in the optimization problem improves the convergence of the optimization process, by simplifying the linear constraints [31]. Using this algorithm, the load-energy curve can be approximated precisely, even with a small number of straight lines, as shown in Figure 4. Here, the load-energy curve is depicted as a solid line, and the piecewise linear curve resulting from application of this algorithm is depicted as a dashed line. This algorithm constructs the piecewise linear curve by selecting N_{AP} points on the load-energy curve.




Figure 4. Piecewise linear load-energy curve constructed using the Douglas-Peucker algorithm.

4.2. Impact of the Renewable Electrical Power Source

In conventional expansion planning problems, the residual LDC (RLDC) is utilized instead of the LDC to analyze the impact of adopting a renewable electrical power source, which is treated as a negative load. The RLDC is formed by subtracting the chronological output pattern of the renewable electrical power source from the chronological load pattern and sorting this curve in descending order. To adopt the renewable electrical power source in the optimization process, the RLDC can be used. In our work, a residual load-energy curve should be constructed from the RLDC to analyze the renewable electrical power source, because the load-energy curve is used instead of the LDC.

The renewable electrical power source is no longer treated as a generation resource, because its generation amount is reflected in the residual load-energy curve. For this reason, the problem of deciding whether to adopt this resource is equivalent to choosing between the load-energy curve and the residual load-energy curve. If this resource is adopted, the residual load-energy curve is selected; otherwise, the load-energy curve is selected. The status of a candidate electrical load-energy curve is defined mathematically as:

$$u_{ELPAT}^{1,y} \geq 0, u_{ELPAT}^{2,y} = \sum_{i=1}^{N_{ER}} \left(\rho_{RES,e}^i \cdot \left[\sum_{si=1}^{N_{EST}} u_e^{i,si,y} \right] \right) \quad \forall y. \tag{12}$$

The status of the candidate electrical load-energy curve denoted $u_{ELPAT}^{1,y}$ is 1 if the LDC is selected; otherwise the status denoted $u_{ELPAT}^{2,y}$ is 1. In addition, only one of the statuses of the candidate electrical load-energy curves can have a value of 1, as shown in Equation (13), since these curves cannot be selected at the same time in one project year:

$$\sum_{elp=1}^{N_{ELPAT}} u_{ELPAT}^{elp,y} = 1 \quad \forall y. \tag{13}$$

The operation cost of the renewable electrical power resource cannot be estimated in the same way as other resources, because the utilized energy of this resource is reflected using the residual load-energy curve. Hence, the total energy difference between the load-energy curve and the residual

load-energy curve is treated as the utilized energy of this resource. This difference is reflected in the estimation of the operation cost of the renewable electrical power source, as follows:

$$\begin{aligned} \text{COST}_{RES,e}^y &= \sum_{i=1}^{N_{ER}} \rho_{RES,e}^i \cdot (1 + \gamma_d)^{-y} \cdot \left((CRF^i \cdot CC_e^i + FOMC_e^i) \cdot C_e^{i,1} \cdot \left[\sum_{si=1}^{N_{EST}} u_e^{i,si,y} \right] \right) \\ &+ \sum_{i=1}^{N_{ER}} \rho_{RES,e}^i \cdot (1 + \gamma_d)^{-y} \cdot \left(VOMC_e^i \cdot \left[\max_{eap \in EAP} (ed_e^{1,eap,y}) - \max_{eap \in EAP} (ed_e^{2,eap,y}) \right] \cdot \left[\sum_{si=1}^{N_{EST}} u_e^{i,si,y} \right] \right) \end{aligned} \quad (14)$$

Although the method for estimating fixed costs of this resource is similar to the method used for other resources, only a single candidate unit, $C_e^{i,1}$, is only used. This is because the RLDC depends on the output of a resource that varies with the capacity of the candidate unit.

The cost of the renewable electrical power source is not reflected in the total cost of electrical energy resources, as shown in Equation (2). Thus, the total cost of electrical energy should be modified considering the renewable electrical power source. Equation (15) defines the total cost including the modification. First, the cost of other resources is distinguished from the cost of the renewable energy resource by using the index, $\rho_{RES,e}^i$. Then, the cost of the renewable energy resource, as defined in Equation (14), is added to the total cost of the other resources as follows:

$$\begin{aligned} \text{COST}_e^y &= \sum_{i=1}^{N_{ER}} (1 - \rho_{CHP,e}^i) \cdot (1 - \rho_{RES,e}^i) \cdot (1 + \gamma_d)^{-y} \cdot (CRF^i \cdot CC_e^i + FOMC_e^i) \cdot \left[\sum_{c=1}^{N_c} C_e^{i,c} \cdot v_e^{i,c,y} \right] \\ &+ \sum_{i=1}^{N_{ER}} (1 - \rho_{CHP,e}^i) \cdot (1 - \rho_{RES,e}^i) \cdot (1 + \gamma_d)^{-y} \cdot (FC_e^i + VOMC_e^i) \cdot \left[\sum_{si=1}^{N_{EST}} E_e^{i,si,y} \right] + \text{COST}_{RES,e}^y \quad \forall y. \end{aligned} \quad (15)$$

Enough resources must be allocated in expansion planning such that the energy procured meets demand. Therefore, the total sum of the desired capacity and that of the utilized energy should be equal to, or over, the maximum load demand and the maximum energy demand, including the energy demand and the charging energy, respectively, as defined below:

$$\sum_{i=1}^{N_{ER}} \sum_{si=1}^{N_{EST}} P_e^{i,si,y} \geq \sum_{elp=1}^{N_{ELPAT}} \left(\max_{eap \in EAPS} (ld_e^{elp,eap,y}) \cdot u_{ELPAT}^{elp,y} \right), \sum_{j=1}^{N_{HR}} \sum_{sj=1}^{N_{HST}} P_h^{j,sj,y} \geq \max_{hap \in HAPS} (ld_h^{hap,y}) \quad \forall y \quad (16)$$

$$\begin{aligned} \sum_{i=1}^{N_{ER}} \sum_{si=1}^{N_{EST}} E_e^{i,si,y} &\geq \sum_{elp=1}^{N_{ELPAT}} \left(\max_{eap \in EAPS} (ed_e^{elp,eap,y}) \cdot u_{ELPAT}^{elp,y} \right) + \sum_{si=1}^{N_{EST}} e_{ESS}^{si,y} \quad \forall y, \\ \sum_{j=1}^{N_{HR}} \sum_{sj=1}^{N_{HST}} E_h^{j,sj,y} &\geq \max_{hap \in HAPS} (ed_h^{hap,y}) + \sum_{sj=1}^{N_{HST}} e_{TSS}^{sj,y} \quad \forall y. \end{aligned} \quad (17)$$

In expansion planning, the maximum load demand and energy demand can be changed by the statuses of the candidate electrical load patterns.

5. Optimization Process

5.1. Proposed Optimization Method

In our study, the installed capacity and the utilized energy of the energy resources are determined using a piecewise linear load-energy curve. For optimal allocation of the installed capacity and the utilized energy of the resources, a special ordered set of type 2 (SOS2) is used, which is known to be efficient for finding solutions to MILP problems [32]. Figure 5 illustrates the optimization process for determining a candidate resource. In the SOS2 method, as shown in Figure 5a, two adjacent SOS2 variables, $\omega^{2,y}$, $\omega^{3,y}$, are multiplied by the corresponding boundary node points to search for the desired load point, p^y , and energy point, e^y . After the desired points are located, the space, called a stack, between two adjacent desired points can be estimated and allocated to the candidate resource. Figure 5b depicts the desired capacity, $P^{2,y}$, and the utilized energy, $E^{2,y}$, determined using the stack between the two adjacent desired points. In the same way, N_{ST} stacks can be configured, to allocate the resources.




Figure 5. Optimization process for determining the candidate resource: (a) Determining the desired point using the SOS2 method; (b) Allocating the capacity and utilized energy of a candidate resource.

Equations (18)–(24) detail the process for allocating the desired capacity and the utilized energy of the energy resources. In Equation (18), the value of the SOS2 variable is set to be less than the sum of the statuses of the two adjacent candidate segments:

$$\begin{aligned} \omega_e^{elp,si,eap,y} &\leq bs_e^{elp,si,eap-1,y} + bs_e^{elp,si,eap,y} \quad \forall elp, \forall eap, \forall si, \forall y, (bs_e^{elp,si,0,y} = 0) \\ \omega_h^{sj,hap,y} &\leq bs_h^{sj,hap-1,y} + bs_h^{sj,hap,y} \quad \forall hap, \forall sj, \forall y, (bs_h^{sj,0,y} = 0). \end{aligned} \quad (18)$$

According to the definition of the SOS2 method, the sum of two adjacent SOS2 variables must be 1, for one stack over one project year:

$$\sum_{eap=1}^{NEAP} \omega_e^{elp,si,eap,y} = u_{ELPAT}^{elp,y}, \quad \sum_{hap=1}^{NHAP} \omega_h^{sj,hap,y} = 1 \quad \forall elp, \forall si, \forall sj, \forall y. \quad (19)$$

A candidate segment must be selected once, for one stack over one project year:

$$\sum_{eseg=1}^{NESEG} bs_e^{elp,si,eap,y} = u_{ELPAT}^{elp,y}, \quad \sum_{hseg=1}^{NHSEG} bs_h^{sj,hap,y} = 1 \quad \forall elp, \forall si, \forall sj, \forall y. \quad (20)$$

The desired point for determining the stack in the piecewise linear load-energy curve is estimated as follows:

$$p_e^{si,y} = \sum_{elp=1}^{NELPAT} \sum_{eap=1}^{NEAP} ld_e^{elp,eap,y} \cdot \omega_e^{elp,si,eap,y}, \quad p_h^{sj,y} = \sum_{hap=1}^{NHAP} ld_h^{hap,y} \cdot \omega_h^{sj,hap,y} \quad \forall si, \forall sj, \forall y \quad (21)$$

$$e_e^{si,y} = \sum_{elp=1}^{NELPAT} \sum_{eap=1}^{NEAP} ed_e^{elp,eap,y} \cdot \omega_e^{elp,si,eap,y}, \quad e_h^{sj,y} = \sum_{hap=1}^{NHAP} ed_h^{hap,y} \cdot \omega_h^{sj,hap,y} \quad \forall si, \forall sj, \forall y. \quad (22)$$

After determining the desired points, the desired capacity and the utilized energy are allocated by calculating the difference between the desired points as below:

$$\sum_{i=1}^{NER} P_e^{i,si,y} = \begin{cases} p_e^{si,y}, & \text{if } si = 1 \\ p_e^{si,y} - p_e^{si-1,y}, & \text{otherwise} \end{cases}, \quad \sum_{j=1}^{NHR} P_h^{j,sj,y} = \begin{cases} p_h^{sj,y}, & \text{if } sj = 1 \\ p_h^{sj,y} - p_h^{sj-1,y}, & \text{otherwise} \end{cases} \quad (23)$$

$$\sum_{i=1}^{NER} E_e^{i,si,y} = \begin{cases} e_e^{si,y} + e_{EES}^{si,y}, & \text{if } si = 1 \\ e_e^{si,y} - e_e^{si-1,y} + e_{EES}^{si,y}, & \text{otherwise} \end{cases}, \quad \sum_{j=1}^{NHR} E_h^{j,sj,y} = \begin{cases} e_h^{sj,y} + e_{TES}^{sj,y}, & \text{if } sj = 1 \\ e_h^{sj,y} - e_h^{sj-1,y} + e_{TES}^{sj,y}, & \text{otherwise} \end{cases} \quad (24)$$

Since the charging energy of the energy storage resources is not included in the load-energy curve, it is added to the utilized energy in Equation (24). The status of the candidate energy resource, $u_e^{i,si,y}$, $u_h^{j,sj,y}$, which is used for resource allocation of the stack, is defined as:

$$u_e^{i,si,y} = \begin{cases} 1, & \text{if } si \text{ is allocated to } i \\ 0, & \text{otherwise} \end{cases} \quad \forall i, \forall si, \forall y, \tag{25}$$

$$u_h^{j,sj,y} = \begin{cases} 1, & \text{if } sj \text{ is allocated to } j \\ 0, & \text{otherwise} \end{cases} \quad \forall j, \forall sj, \forall y.$$

In Equations (26) and (27), the stack allocated to the candidate resource can be as large as the maximum capacity of the candidate unit of the specific resource. In these equations, the renewable electrical power source should be excepted since the output of this resource is reflected in the residual load-energy curve:

$$P_e^{i,si,y} \leq \max_{c \in \text{CANDIDATES}} (C_e^{i,c}) \cdot (1 - \rho_{RES,e}^i) \cdot u_e^{i,si,y}, P_h^{j,sj,y} \leq \max_{c \in \text{CANDIDATES}} (C_h^{j,c}) \cdot u_h^{j,sj,y} \tag{26}$$

$$E_e^{i,si,y} \leq \max_{c \in \text{CANDIDATES}} (C_e^{i,c}) \cdot (1 - \rho_{RES,e}^i) \cdot u_e^{i,si,y} \cdot 8760, E_h^{j,sj,y} \leq \max_{c \in \text{CANDIDATES}} (C_h^{j,c}) \cdot u_h^{j,sj,y} \cdot 8760. \tag{27}$$

In Equations (28) and (29), it is assumed that the stack is in charge of no more than one resource:

$$\sum_{i=1}^{N_{ER}} u_e^{i,si,y} \leq 1, \sum_{j=1}^{N_{HR}} u_h^{j,sj,y} \leq 1 \quad \forall si, \forall sj, \forall y \tag{28}$$

$$\sum_{si=1}^{N_{EST}} u_e^{i,si,y} \leq 1, \sum_{sj=1}^{N_{HST}} u_h^{j,sj,y} \leq 1 \quad \forall i, \forall j, \forall y. \tag{29}$$

The candidate unit of the resource should also be selected, because these units have different capacity. To select the candidate unit, the status of a candidate generating unit is designed as:

$$v_e^{i,c,y} = \begin{cases} 1, & \text{if } c \text{ of } i \text{ is chosen} \\ 0, & \text{otherwise} \end{cases}, v_h^{j,c,y} = \begin{cases} 1, & \text{if } c \text{ of } j \text{ is chosen} \\ 0, & \text{otherwise} \end{cases} \quad \forall i, \forall j, \forall c, \forall y. \tag{30}$$

In addition, no more than one candidate unit should be selected, as shown in Equation (31), and the candidate unit should only be selected if any stack is allocated to the resource, as shown in Equation (32):

$$\sum_{c=1}^{N_C} v_e^{i,c,y} \leq 1, \sum_{c=1}^{N_C} v_h^{j,c,y} \leq 1 \quad \forall i, \forall j, \forall y \tag{31}$$

$$\sum_{c=1}^{N_C} v_e^{i,c,y} = \sum_{si=1}^{N_{EST}} u_e^{i,si,y}, \sum_{c=1}^{N_C} v_h^{j,c,y} = \sum_{sj=1}^{N_{HST}} u_h^{j,sj,y} \quad \forall i, \forall j, \forall y. \tag{32}$$

In the previous process for allocating the resource, the maximum stack size is determined using Equations (26) and (27). However, these constraints are not sufficient for determining the desired capacity and the utilized energy, since the stack size is modified as the capacity of the candidate unit as follows:

$$\sum_{si=1}^{N_{EST}} P_e^{i,si,y} \leq (1 - \rho_{RES,e}^i) \cdot \left[\sum_{c=1}^{N_C} (C_e^{i,c} \cdot v_e^{i,c,y}) \right], \sum_{sj=1}^{N_{HST}} P_h^{j,sj,y} \leq \sum_{c=1}^{N_C} C_h^{j,c} \cdot v_h^{j,c,y} \quad \forall i, \forall j, \forall y. \tag{33}$$

To remove the impact of the renewable electrical power source on resource allocation, it is excluded from the stack size constraint for electrical energy resources. The maximum utilized energy is defined by the capacity of the candidate unit of the resource as below:

$$\begin{aligned} \sum_{si=1}^{N_{EST}} E_e^{i,si,y} &\leq \left(1 - \rho_{RES,e}^i\right) \cdot \left[\sum_{c=1}^{N_C} \left(C_e^{i,c} \cdot v_e^{i,c,y}\right)\right] \cdot 8760 \quad \forall i, \forall y \\ \sum_{sj=1}^{N_{HST}} E_h^{j,sj,y} &\leq \left[\sum_{c=1}^{N_C} \left(C_h^{j,c} \cdot v_h^{j,c,y}\right)\right] \cdot 8760 \quad \forall j, \forall y. \end{aligned} \quad (34)$$

5.2. Comparison of Optimization Results Using Different Load Curves

In this section, we examine the effectiveness of the proposed method with reference to a conventional method that uses a stepwise representation of the LDC. We compare the results of energy expansion planning for a single year using the non-linearized LDC, the stepwise representation of the LDC, and the piecewise linear load-energy curve. The objective of this problem is to minimize the total cost of the installed capacity and utilized energy of the two generators according to the cost data presented in Table 1. For intuitive comparison of the results, we assume simplified cost data represented by the fixed cost and variable cost. On the basis of these data, G1 is expected to supply the majority of the load, whereas G2 supplies the shortfall of this load.

Table 1. Cost data for two generator units.

| Unit | Fixed Cost (\$/MW) (Capital Cost + Fixed Operations & Maintenance Cost) | Variable Cost (\$/MWh) (Fuel Cost + Variable Operations & Maintenance Cost) |
|------|---|---|
| G1 | 60,000 | 100 |
| G2 | 10,000 | 200 |

The load is assumed to be as depicted in Figure 6. Figure 6a shows the LDC, depicted using a solid line, and the stepwise representation of the LDC, depicted using a dashed line. The piecewise linear load-energy curve is illustrated in Figure 6b. The number of segments in the stepwise representation of the LDC is made equal to the number of segments in the piecewise linear load-energy curve. As shown in Figure 6, these curves are approximated by seven segments, such that the approximation error is less than 1%.

The results of the optimization performed using the data mentioned above are summarized in Table 2. We define the models used to obtain the results as Model 0, where the non-linearized LDC was used; Model 1, where the stepwise representation of the LDC was used; and Model 2, where the piecewise linear load-energy curve was used. The results are listed according to the model, and the total cost, desired capacity, and utilized energy of the resources are compared. In this table, the errors in the results obtained using the approximated curves are estimated by comparison with the results of Model 0, and are expressed as percentages.

Table 2. Results of the expansion planning problem.

| Model No. | Type of Curve | Total Cost (M\$) | Desired Capacity of G1 (MW) | Utilized Energy of G1 (GWh) | Desired Capacity of G2 (MW) | Utilized Energy of G2 (GWh) |
|-----------|------------------------------------|------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|
| 0 | LDC | 858.9 | 1087.2 | 7885 | 126.0 | 19.9 |
| 1 | Stepwise representation of LDC | 866.8 (0.92%) | 1028.8 (5.37%) | 7780 (1.33%) | 184.4 (46.35%) | 126.1 (533.7%) |
| 2 | Piecewise linear load-energy curve | 861.5 (0.31%) | 1080 (0.66%) | 7855 (0.38%) | 133.2 (5.68%) | 49.7 (150.3%) |

Overall, the results of Model 2 are better than those of Model 1. The error in total cost for Model 1 is 0.92%, which is 0.61% greater than the error for Model 2. The results for the desired capacity and utilized energy of G1 and G2 are more accurate when Model 2 is used than when Model 1 is

used, as defined by their similarity to the results of Model 0. In particular, the error in the results for the desired capacity and utilized energy of G2 is more than three times larger with Model 1 than with Model 2. Therefore, it is better to use the piecewise linear load-energy curve to formulate the MILP problem than a stepwise representation of the LDC.




Figure 6. Load curves used in analysis: (a) LDC and stepwise representation of LDC; (b) Piecewise linear load-energy curve.

6. Case Study

In this section, we discuss the results of applying the proposed energy expansion planning method to an actual multi-energy system.

6.1. Data and Assumptions

We evaluated the proposed method using a comprehensive multi-energy system based on a benchmark determined by the energy system for Goyang city in Korea, which supplies electricity and heat with a 900 MW cogenerator. The cost parameters of the system are summarized in Table 3.

Table 3. Cost parameters used in multi-energy system expansion planning.

| Parameter | Value |
|-----------------------------------|-------|
| Project lifetime (Year) | 7 |
| Interest rate (%) | 3.91 |
| Demand growth rate (%) | 2.5 |
| Approximation error tolerance (%) | 1 |

The project lifetime is assumed to be seven years, based on the lifespan of the electrical energy storage units [33]. The annual interest rate is considered to be 3.91% [34]. The rate of demand growth is

assumed to be 2.5%, and the demand pattern is assumed to be the same each year. The approximation error tolerance of the Douglas-Peucker algorithm is 1%, to ensure accuracy, and reduce the computation burden, simultaneously. The energy load profiles are illustrated in Figure 7, where the heat load and electricity load profiles of the city are depicted in Figure 7a,b, respectively [35,36]. In addition, the LDCs for given loads are described in Figure 7c,d, respectively.




Figure 7. Load profiles for the first project year: (a) Electricity load; (b) Heat load; (c) Load duration curve for electricity load; (d) Load duration curve for heat load.

We constructed the load-energy curves for electricity and heat using these profiles, and linearized them using the Douglas-Peucker algorithm, as shown in Figure 8. As a result of the error tolerance of the Douglas-Peucker algorithm, defined in Table 3, there are 6 and 58 segments in the piecewise linear load-energy curve for electricity and heat, respectively.

The renewable electrical power source is assumed to be a photovoltaic generator with a 13.3 MW capacity, where the output pattern for one year is as depicted in Figure 9 [37]. Using this pattern, the capacity factor of this resource was estimated below 11%.

Table 4 shows the costs, life span, and candidate capacity of the candidate energy generation and energy storage resources used in this study. We defined the cost and life span of each resource as the average cost of the resource technology [33,38].

Among the technologies for energy generation resources, the multi-energy system would be expected to use gas-based and diesel-based resources, as these resources could be suitable for small-scale energy systems rather than bulk energy systems. Therefore, we assumed that the fuel-based power generators, DG1, DG2, and DG3, were based on a gas peaking, a diesel reciprocating, and a natural gas reciprocating engine generator, respectively. In addition, the heat-only boilers, HOB1 and HOB2, were assumed to be based on a gas boiler and a diesel boiler, respectively. Similarly, CHP was assumed to be based on a gas combined cycle. Further, the EES, TES, and PV were based on lithium ion battery energy storage, thermal energy storage, and solar photovoltaic generator, respectively. The candidate capacity of each resource was assumed according to the output capacity of multiple units, and the capacity of the CHP unit was defined on the basis of the performance of the 900 MW generator used in Goyang city. In addition, the heat-to-power ratio of the CHP unit was defined as 0.92.




Figure 8. Piecewise linear load-energy curves for the first project year: (a) Electricity load; (b) Heat load.




Figure 9. Output pattern of the renewable electrical power source.

Table 4. Energy resources data (O&M = operations and maintenance).

| Resource Type | Unit Name | Overnight Capital Cost (\$/MW) | Fixed O&M Cost (\$/MW) | Fuel Cost (\$/MWh) | Variable O&M Cost (\$/MWh) | Life Span (Yr) | Candidate Capacity (MW) |
|-----------------------------------|-----------|--------------------------------|------------------------|--------------------|----------------------------|----------------|--|
| Fuel-based Power Generator | DG1 | 900,000 | 15,000 | 33.2925 | 6.1 | 20 | 800, 700, 600, 500, 400, 300 |
| | DG2 | 650,000 | 15,000 | 182.3 | 15 | 20 | 90, 80, 70, 60, 50, 40 |
| | DG3 | 875,000 | 17,500 | 46.75 | 12.5 | 20 | 90, 80, 70, 60, 50, 40 |
| Heat Only Boiler | HOB1 | 720,000 | 12,000 | 26.634 | 4.88 | 20 | 500, 450, 400, 350, 300, 250 |
| | HOB2 | 520,000 | 15,000 | 182.3 | 15 | 20 | 400, 350, 300, 250, 200, 150 |
| CHP | CHP | 1,150,000 | 5850 | 22.77 | 2.75 | 20 | 900, 800, 700, 600, 500, 400 (Heat-to-Power ratio: 0.92) |
| Electrical Energy Storage | EES | 3,092,000 | 42,000 | 0 | 35 | 7 | 24, 20, 16, 12, 8, 4 |
| Thermal Energy Storage | TES | 3,184,000 | 52,000 | 0 | 35 | 7 | 24, 20, 16, 12, 8, 4 |
| Renewable Electrical Power Source | PV | 1,375,000 | 10,500 | 0 | 0 | 20 | 13.3 |

6.2. Simulation Results

Table 5 shows four configurations of energy resources, defined so that the impact of adopting different combinations of energy resources could be analyzed. The fuel-based power generators, heat only boilers, and the CHP unit were included in all cases. To assess the impact of the other resources individually, the energy storage resources and renewable electrical power source were included in Case 2 and Case 3, respectively. Finally, in Case 4, we considered expansion planning using all the available resources.

Table 5. Configurations of energy resources used in expansion planning.

| Case Number | Fuel-Based Power Generator | Heat Only Boiler | CHP | Storage | | Renewable Electrical Power Source |
|-------------|----------------------------|------------------|-----|-------------------|----------------|-----------------------------------|
| | | | | Electrical Energy | Thermal Energy | |
| 1 | ○ | ○ | ○ | - | - | - |
| 2 | ○ | ○ | ○ | ○ | ○ | - |
| 3 | ○ | ○ | ○ | - | - | ○ |
| 4 | ○ | ○ | ○ | ○ | ○ | ○ |

The proposed method was implemented in FICO Xpress and solved using standard branch-and-bound and simplex algorithms. The branch-and-bound algorithm was set to stop when a 0.1% duality gap was reached. The seven-year planning results for the four cases are presented in Tables 6 and 7. These tables show the planning schedule results, which describe the adopted resources, the capacity secured from each resource, and the amount of energy generated by each resource, over the project years. The cost-by-case results are shown in Figure 10. This figure shows the total cost, variable costs, and fixed costs, for each case. Note that the total cost of each case can be calculated by summing fixed costs and variable costs.




Figure 10. Estimated costs by case. (Note that, in the Case 3 and 4, (a) means a case with forced allocation of RES and (b) means a case without forced allocation of RES).

Table 6. Seven-year planning schedules for Cases 1, 2, and 3 (RES = renewable electrical power source).

| Year | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | |
|----------|-------------------------|-------|---|----------------|----------------|----------------|----------------|----------------|----------------|
| Case No. | Forced Allocated of RES | Unit | Installed Capacity (MW)/Utilized Energy (GWh) | | | | | | |
| 1 | - | DG1 | 700/5553 | 700/5692 | 700/5834 | 700/5980 | 700/6110 | 700/6114 | 700/6118 |
| | | DG2 | - | - | - | - | - | - | - |
| | | DG3 | - | - | - | - | 40/18.83 | 40/168.3 | 40/321.5 |
| | | HOB1 | 250/152.3 | 250/155.7 | 250/159.3 | 250/162.9 | 250/166.7 | 250/170.5 | 250/174.4 |
| | | HOB2 | 250/9.488 | 250/10.062 | 250/10.65 | 250/11.25 | 250/11.87 | 250/12.51 | 250/13.16 |
| | | CHP * | 700/2352(2164) | 700/2411(2218) | 700/2471(2273) | 700/2533(2330) | 700/2596(2388) | 700/2661(2448) | 700/2728(2509) |
| 2 | - | DG1 | 700/5553 | 700/5692 | 700/5840 | 700/6010 | 700/6110 | 700/6114 | 700/6118 |
| | | DG2 | - | - | 60/0.2462 | 60/0.7965 | 60/1.349 | 60/1.915 | 60/2.576 |
| | | DG3 | - | - | - | - | 50/75.33 | 50/252.1 | 50/417.8 |
| | | HOB1 | 300/155.0 | 300/158.4 | 300/167.5 | 300/192.8 | 300/220.7 | 300/249.4 | 300/263.0 |
| | | HOB2 | 250/6.792 | 250/7.366 | 250/8.264 | 250/9.619 | 250/11.01 | 250/12.43 | 250/15.63 |
| | | EES | - | - | - | - | - | - | - |
| | | TES | - | - | - | - | - | - | 8/14.08 |
| | | CHP * | 600/2352(2164) | 600/2411(2218) | 600/2465(2267) | 600/2502(2302) | 600/2538(2335) | 600/2575(2369) | 600/2629(2418) |
| 3 | No | DG1 | 700/5553 | 700/5692 | 700/5834 | 700/5980 | 700/6110 | 700/6114 | 700/6118 |
| | | DG2 | - | - | - | - | - | - | - |
| | | DG3 | - | - | - | - | 40/18.83 | 40/168.3 | 40/321.5 |
| | | HOB1 | 250/152.3 | 250/155.7 | 250/159.3 | 250/162.9 | 250/166.7 | 250/170.5 | 250/174.4 |
| | | HOB2 | 250/9.488 | 250/10.062 | 250/10.65 | 250/11.25 | 250/11.87 | 250/12.51 | 250/13.16 |
| | | CHP * | 700/2352(2164) | 700/2411(2218) | 700/2471(2273) | 700/2533(2330) | 700/2596(2388) | 700/2661(2448) | 700/2728(2509) |
| | | PV | - | - | - | - | - | - | - |
| 3 | Yes | DG1 | 700/5551 | 700/5690 | 700/5832 | 700/5978 | 700/6110 | 700/6114 | 700/6118 |
| | | DG2 | - | - | - | - | - | - | - |
| | | DG3 | - | - | - | - | 40/16.78 | 40/166.2 | 40/319.4 |
| | | HOB1 | 250/152.3 | 250/155.7 | 250/159.3 | 250/162.9 | 250/166.7 | 250/170.5 | 300/177.1 |
| | | HOB2 | 250/9.49 | 250/10.06 | 250/10.65 | 250/11.25 | 250/11.87 | 250/12.51 | 200/10.46 |
| | | CHP * | 700/2352(2164) | 700/2411(2218) | 700/2471(2273) | 700/2533(2330) | 700/2596(2388) | 700/2661(2448) | 700/2728(2509) |
| | | PV | 13.3/2.079 | 13.3/2.079 | 13.3/2.079 | 13.3/2.079 | 13.3/2.079 | 13.3/2.079 | 13.3/2.079 |

* CHP Shows Generated Electrical and Thermal Energy Together—Electrical Energy (Thermal Energy).

Table 7. Seven-year planning schedules for Case 4.

| Year | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | |
|----------|--------------------------|-------|---|----------------|----------------|----------------|----------------|----------------|----------------|
| Case No. | Forced Allocation of RES | Unit | Installed Capacity (MW)/Utilized Energy (GWh) | | | | | | |
| 4 | No | DG1 | 700/5553 | 700/5692 | 700/5840 | 700/6010 | 700/6110 | 700/6114 | 700/6118 |
| | | DG2 | - | - | 60/0.2462 | 60/0.7965 | 60/1.349 | 60/1.915 | 60/2.576 |
| | | DG3 | - | - | - | - | 50/75.33 | 50/252.1 | 50/417.8 |
| | | HOB1 | 300/155.0 | 300/158.4 | 300/167.5 | 300/192.8 | 300/220.7 | 300/249.4 | 300/263.0 |
| | | HOB2 | 250/6.792 | 250/7.366 | 250/8.264 | 250/9.619 | 250/11.01 | 250/12.43 | 250/15.63 |
| | | EES | - | - | - | - | - | - | - |
| | | TES | - | - | - | - | - | - | 8/14.08 |
| | | CHP * | 600/2352(2164) | 600/2411(2218) | 600/2465(2267) | 600/2502(2302) | 600/2538(2335) | 600/2575(2369) | 600/2629(2418) |
| | | PV | - | - | - | - | - | - | - |
| 4 | Yes | DG1 | 700/5551 | 700/5690 | 700/5838 | 700/6008 | 700/6110 | 700/6114 | 700/6118 |
| | | DG2 | - | - | 60/0.246 | 60/0.798 | 60/1.352 | 60/1.920 | 60/2.582 |
| | | DG3 | - | - | - | - | 50/73.24 | 50/250.0 | 50/415.7 |
| | | HOB1 | 300/155.0 | 300/158.4 | 300/167.5 | 300/192.8 | 300/220.7 | 300/249.4 | 300/263.0 |
| | | HOB2 | 250/6.793 | 250/7.367 | 250/8.264 | 250/9.619 | 250/11.01 | 250/12.43 | 250/15.63 |
| | | EES | - | - | - | - | - | - | - |
| | | TES | - | - | - | - | - | - | 8/14.08 |
| | | CHP * | 600/2352(2164) | 600/2411(2218) | 600/2465(2267) | 600/2502(2302) | 600/2538(2335) | 600/2575(2369) | 600/2629(2418) |
| | | PV | 13.3/2.079 | 13.3/2.079 | 13.3/2.079 | 13.3/2.079 | 13.3/2.079 | 13.3/2.079 | 13.3/2.079 |

* CHP Shows Electrical and Thermal Energy Together—Electrical Energy (Thermal Energy).

6.2.1. Case 1

In Case 1, we considered the impact of adopting fuel-based power generators, heat only boilers, and the CHP unit. The results of planning for this case, summarized in Table 6, show that DG1, HOB1, HOB2, and CHP are installed from the first project year, and DG3 is added in the fourth project year, because this resource is more expensive than DG1 and CHP. In addition, we note that the utilized electrical and heat energy of the CHP have a heat-to-power ratio of 0.92, matching the value defined in Table 3.

6.2.2. Case 2

In Case 2, we considered energy storage resources, in addition to the generation resources used in Case 1. We note that only TES is added from the available energy storage resources, as summarized in Table 6. Although the total cost and fixed costs are reduced by 0.01% ($\$0.3 \times 10^6$) and 1.5% ($\1.37×10^7), respectively, variable costs increase by 0.72% ($\$1.34 \times 10^7$). Compared to Case 1, the installed capacity of the CHP is reduced by 100 MW, and the utilized energy for the CHP is also reduced. However, resources such as DG2, DG3, and HOB1 are newly added, or extended, since the shortfall due to the reduction of the CHP should be secured. Although the utilizing electrical energy of DG3 is larger than that of DG2, the allocated capacity of DG2 is larger than that of DG3. DG2 delivers more energy at a cheaper variable cost than DG3. The installed capacity and the utilizing heat energy of HOB1 increase, because the installed capacity and the utilized energy of CHP are reduced. We note that TES, in the last project year, is charged from CHP, which has a relatively low variable cost.

6.2.3. Case 3

The renewable electrical power source was included for consideration in Case 3. However, the economic effectiveness of this resource is lower than the other resources, because its capacity factor is low. The schedule results in Table 6 show that, at the cost defined in Table 4, the renewable electrical power resource could not be allocated in the energy plan. Although allocating this resource is not necessary for creating an optimal plan, we tried to compulsorily force its adoption into the planning schedule, to validate its impact. For this reason, we considered two scenarios: one where this resource was forcibly allocated, and another when allocation was unrestricted. Comparing the difference between the two scenarios using Table 6, the utilized energy for DG3, which is the resource with the high variable cost, is reduced by 2.079 GWh, which is the utilized energy of PV, when PV is forced to be allocated. In the forcible allocation scenario, the utilized energy of DG1 is decreased in each year, between the first and the fourth project year, while between the fifth and the last project year, the utilized energy of DG3 is decreased. This suggests that allocating the renewable electrical power source reduces the utilized energy of resources with high variable costs. Due to this reduction, the variable costs in the forcibly allocated scenario are lower than that in the scenario when allocation is not forced, as seen in Figure 10. However, since PV is added in the forcible allocation scenario, the total cost and fixed costs are high.

6.2.4. Case 4

The energy storage resources and renewable electrical power source were included in Case 4. As with Case 3, this case is also divided into a scenario where the renewable electrical power source is forcibly allocated and one where allocation is unrestricted. As shown in Table 7, the renewable electrical power source reduces the utilized energy of the resource, which has a high variable cost. Between the first and fourth project years, the utilized energy of DG1 is decreased in the forcible allocation scenario. From the fifth to the last project years, the utilized energy of DG3 is decreased in the forcible allocation scenario. Although DG2, which has the highest variable cost, is installed in the third project year, its utilized energy is not decreased. This is because the utilized energy of DG3 is small compared to that of the PV, so the configuration of DG2 can be maintained without a reduction

in energy. In terms of the use of energy storage resources, the planning schedule results are similar to those for Case 2, because the PV, with its lower capacity factor, does not change the results dramatically.

Figure 11 shows the results of the planning schedules described above graphically. Note that the energy resources are planned to meet the demand growth considering the presence or absence of forced allocation of RES. As in Case 3, the total cost of the scenario with forcible allocation is higher than that of the scenario where allocation is not forced. Compared to the forcible allocation scenario in Case 3, although the fixed costs are lower, the variable costs are higher, because the installed capacity of the CHP is decreased in this case, owing to utilization of the energy storage resource.




Figure 11. Results of planning schedules for Case 4: (a) Installed capacity of electricity resources without forced allocation of RES; (b) Installed capacity of electricity resources with forced allocation of RES; (c) Utilized energy of electricity resources without forced allocation of RES; (d) Utilized energy of electricity resources with forced allocation of RES; (e) Installed capacity of heat resources without forced allocation of RES; (f) Installed capacity of heat resources with forced allocation of RES; (g) Utilized energy of heat resources without forced allocation of RES; (h) Utilized energy of heat resources with forced allocation of RES.

7. Conclusions

In this paper, we have proposed an optimization approach based on MILP, for expansion planning of a multi-energy system. The objective function of the problem was to minimize the total cost, composed of the investment and the operation cost of the electrical energy resources (including fuel-based power generators, an electrical energy storage, and a renewable electrical power source), the heat energy resources (including heat only boilers and a thermal energy storage), and the CHP unit, over the project years. To formulate the MILP problems, we used linearized load-energy curves instead of LDCs. With the load-energy curve, the energy demand used to calculate the cost of the resources can be utilized without the need for an integration operation, as is the case with the LDC. The Douglas-Peucker algorithm was used to linearly approximate the load-energy curve. The residual load-energy curve was used in defining the renewable electrical power source, for inclusion in the planning process. In the optimization process, the SOS2 approach was used to allocate the energy resources to meet the load and energy. A comparison of the proposed method using the load-energy curve with the conventional optimization method using the stepwise representation of the LDC demonstrated that the proposed method was better able to find the closest approximation to the desired solution, which was obtained by the non-linearized LDC, than the conventional method. We also compared different cases adopting different configurations of energy resources in a multi-energy system based on a benchmark determined using an actual energy system. The total cost and planning schedules were determined according to the cost and type of energy resources. The proposed method can help system operators of multi-energy systems design and optimize their model systems considering different energy resources, which are formulated as linearized constraints that can be easily used in commercial optimization software.

This study did not include an energy flow in which various energy sources can be converted and transferred to other sources. Thus, further studies in this field will focus on energy utilization in which energy sources can be integrated with and converted to other sources. In addition, although the operating region or the variable heat-to-power ratio should be considered in the actual operation of CHPs, the heat-to-power ratio for CHPs in this work was assumed to be constant. Therefore, in further studies, we will have to design linearized constraints that can take into account the actual operation of CHPs while maintaining the optimization model used in this study.

Acknowledgments: This research was supported by the Korea Electric Power Corporation through the Korea Electrical Engineering & Science Research Institute (grant number: R15XA03-55) and Basic Science Research Program through the National Research Foundation of Korea (NRF) funded by the Ministry of Education (2017R1D1A1B03029308).

Author Contributions: All the authors contributed to this work. Woong Ko designed the study, performed the analysis, and wrote the first draft of the paper. Jong-Keun Park contributed to the conceptual approach and thoroughly revised the paper. Mun-Kyeom Kim provided important comments on the modeling and analysis and coordinated the proposed approach in the manuscript. Jae-Haeng Heo contributed to developing the optimization model and checked the simulation environments.

Conflicts of Interest: The authors declare no conflict of interest.

Nomenclature

Indices

| | |
|--------|---|
| y | Project year index, from $[1 : N_Y]$. |
| i | Electrical energy resource index, from $[1 : N_{ER}]$. |
| j | Heat energy resource index, from $[1 : N_{HR}]$. |
| c | Candidate unit index, from $[1 : N_C]$. |
| elp | Electrical load pattern index, from $[1 : N_{ELPAT}]$. |
| eap | Index for node point of approximated electrical load-energy curve, from $[1 : N_{EAP}]$. |
| hap | Index for node point of approximated heat load-energy curve, from $[1 : N_{HAP}]$. |
| si | Index for stack of electrical energy resource, from $[1 : N_{EST}]$. |
| sj | Index for stack of heat energy resource, from $[1 : N_{HST}]$. |
| $eseg$ | Index for segment of approximated electrical load-energy curve, from $[1 : N_{ESEG}]$. |
| $hseg$ | Index for segment of approximated heat load-energy curve, from $[1 : N_{HSEG}]$. |

Variables

| | |
|---------------------------|--|
| $ld_e^{elp,eap,y}$ | Load demand for node point, eap , of the electrical load-energy curve, elp , in project year, y (MW). |
| $ed_e^{elp,eap,y}$ | Energy demand for node point, eap , of the electrical load-energy curve, elp , in project year, y (MWh). |
| $ld_h^{hap,y}$ | Load demand for node point, hap , of the heat load-energy curve in project year, y (MW). |
| $ed_h^{hap,y}$ | Energy demand for node point, hap , of the heat load-energy curve in project year, y (MWh). |
| $\omega_e^{elp,si,eap,y}$ | Special ordered sets of type 2 variable for approximated point, eap , in stack, si , of the electrical load-energy curve, elp , in project year, y . |
| $\omega_h^{sj,hap,y}$ | Special ordered sets of type 2 variable for approximated point, hap , in stack, sj , of the heat load-energy curve in project year, y . |
| $p_e^{si,y}$ | Electrical load demand point for determining stack, si , in project year, y (MW). |
| $e_e^{si,y}$ | Electrical energy demand point for determining stack, si , in project year, y (MWh). |
| $p_h^{sj,y}$ | Heat load demand point for determining stack, sj , in project year, y (MW). |
| $e_h^{sj,y}$ | Heat energy demand point for determining stack, sj , in project year, y (MWh). |
| $P_e^{i,si,y}$ | Desired capacity of the electrical energy resource, i , to which stack, si , is allocated in project year, y (MW). |
| $E_e^{i,si,y}$ | Utilized energy of the electrical energy resource, i , to which stack, si , is allocated in project year, y (MWh). |
| $P_h^{j,sj,y}$ | Desired capacity of the heat energy resource, j , to which stack, sj , is allocated in project year, y (MW). |
| $E_h^{j,sj,y}$ | Utilizing energy of the heat energy resource, j , to which stack, sj , is allocated in project year, y (MWh). |
| $e_{EES}^{si,y}$ | Charging electrical energy of stack, si , in project year, y (MWh). |
| $e_{TES}^{sj,y}$ | Charging thermal energy of stack, sj , in project year, y (MWh). |

Binary Variables

| | |
|---------------------------|--|
| $b_{s_e}^{elp,si,eseg,y}$ | Status of candidate segment, $eseg$, in stack, si , of the electrical load-energy curve, elp , in project year, y . |
| $b_{s_h}^{sj,hseg,y}$ | Status of candidate segment, $hseg$, in stack, sj , of heat load-energy curve in project year, y . |
| $u_e^{i,si,y}$ | Status of candidate electrical energy resource, i , to which stack, si , is allocated in project year, y . |
| $u_h^{j,sj,y}$ | Status of candidate heat energy resource, j , to which stack, sj , is allocated in project year, y . |
| $v_e^{i,c,y}$ | Status of candidate generating unit, c , of electrical energy resource, i , in project year, y . |
| $v_h^{j,c,y}$ | Status of candidate generating unit, c , of heat energy resource, j , in project year, y . |
| $u_{ELPAT}^{elp,y}$ | Status of candidate electrical load-energy curve, elp , in project year, y . |

Parameters

| | |
|------------------|---|
| $C_e^{i,c}$ | Capacity of candidate generating unit, c , of electrical energy resource, i . |
| $C_h^{j,c}$ | Capacity of candidate generating unit, c , of heat energy resource, j . |
| CC_e^i | Capital cost of electrical energy resource, i . |
| CC_h^j | Capital cost of heat energy resource, j . |
| $FOMC_e^i$ | Fixed operation and maintenance cost of electrical energy resource, i . |
| $FOMC_h^j$ | Fixed operation and maintenance cost of heat energy resource, j . |
| FC_e^i | Fuel cost of electrical energy resource, i . |
| FC_h^j | Fuel cost of heat energy resource, j . |
| $VOMC_e^i$ | Variable operation and maintenance cost of electrical energy resource, i . |
| $VOMC_h^j$ | Variable operation and maintenance cost of heat energy resource, j . |
| LT_e^i | Lifetime of electrical energy resource, i . |
| LT_h^j | Lifetime of heat energy resource, j . |
| $\rho_{CHP,e}^i$ | Index of CHP unit in electrical energy resource, i . |
| $\rho_{CHP,h}^j$ | Index of CHP unit in heat energy resource, j . |
| ρ_{EES}^i | Index of electrical energy storage in electrical energy resource, i . |
| ρ_{TES}^j | Index of thermal energy storage in heat energy resource, j . |
| $\rho_{RES,e}^i$ | Index of renewable electrical power source in electrical energy resource, i . |
| α_{HPR} | Heat-to-power ratio |
| γ_d | Interest rate |

References

1. Abdollahi, E.; Wang, H.; Rinne, S.; Lahdelma, R. In Optimization of energy production of a CHP plant with heat storage. In Proceedings of the 2014 IEEE Green Energy and Systems Conference (IGESC), Long Beach, CA, USA, 24 November 2014; pp. 30–34.
2. Mancarella, P. MES (multi-energy systems): An overview of concepts and evaluation models. *Energy* **2014**, *65*, 1–17. [[CrossRef](#)]
3. Shahidepour, M.; Yong, F.; Wiedman, T. Impact of Natural Gas Infrastructure on Electric Power Systems. *Proc. IEEE* **2005**, *93*, 1042–1056. [[CrossRef](#)]
4. Kalam, A.; King, A.; Moret, E.; Weerasinghe, U. Combined heat and power systems: Economic and policy barriers to growth. *Chem. Cent. J.* **2012**, *6*, S3. [[CrossRef](#)] [[PubMed](#)]
5. Borelli, D.; Devia, F.; Lo Cascio, E.; Schenone, C.; Spoladore, A. Combined Production and Conversion of Energy in an Urban Integrated System. *Energies* **2016**, *9*, 817. [[CrossRef](#)]
6. Lo Cascio, E.; Borelli, D.; Devia, F.; Schenone, C. Future distributed generation: An operational multi-objective optimization model for integrated small scale urban electrical, thermal and gas grids. *Energy Convers. Manag.* **2017**, *143* (Suppl. C), 348–359. [[CrossRef](#)]
7. Vandewalle, J.; Keyaerts, N.; Haeseleer, W.D. In The role of thermal storage and natural gas in a smart energy system. In Proceedings of the 2012 9th International Conference on the European Energy Market, Florence, Italy, 10–12 May 2012; pp. 1–9.
8. Unsihuay-Vila, C.; Marangon-Lima, J.; de Souza, A.Z.; Perez-Arriaga, I.J.; Balestrassi, P.P. A model to long-term, multiarea, multistage, and integrated expansion planning of electricity and natural gas systems. *IEEE Trans. Power Syst.* **2010**, *25*, 1154–1168. [[CrossRef](#)]
9. Chaudry, M.; Jenkins, N.; Qadrdan, M.; Wu, J. Combined gas and electricity network expansion planning. *Appl. Energy* **2014**, *113*, 1171–1187. [[CrossRef](#)]
10. Moradi, M.H.; Hajinazari, M.; Jamsab, S.; Paripour, M. An energy management system (EMS) strategy for combined heat and power (CHP) systems based on a hybrid optimization method employing fuzzy programming. *Energy* **2013**, *49*, 86–101. [[CrossRef](#)]
11. Salgado, F.; Pedrero, P. Short-term operation planning on cogeneration systems: A survey. *Electr. Power Syst. Res.* **2008**, *78*, 835–848. [[CrossRef](#)]
12. Wouters, C.; Fraga, E.S.; James, A.M. An energy integrated, multi-microgrid, MILP (mixed-integer linear programming) approach for residential distributed energy system planning—A South Australian case-study. *Energy* **2015**, *85* (Suppl. C), 30–44. [[CrossRef](#)]

13. Geidl, M.; Koepfel, G.; Favre-Perrod, P.; Klockl, B.; Andersson, G.; Frohlich, K. Energy hubs for the future. *IEEE Power Energy Mag.* **2007**, *5*, 24–30. [[CrossRef](#)]
14. Shahmohammadi, A.; Moradi-Dalvand, M.; Ghasemi, H.; Ghazizadeh, M.S. Optimal Design of Multicarrier Energy Systems Considering Reliability Constraints. *IEEE Trans. Power Del.* **2015**, *30*, 878–886. [[CrossRef](#)]
15. Dzobo, O.; Xia, X. Optimal operation of smart multi-energy hub systems incorporating energy hub coordination and demand response strategy. *J. Renew. Sustain. Energy* **2017**, *9*, 045501. [[CrossRef](#)]
16. Yu, S.; Zhang, S.; Sun, Y.; Tang, S. In Research on Interaction and Coupling of Various Energy Flows in Micro Energy Internets. In Proceedings of the 2017 IEEE International Conference on Energy Internet (ICEI), Beijing, China, 17–21 April 2017; pp. 53–58.
17. Mozafari, Y.; Rosehart, W.; Zareipour, H. In Integrated electricity generation, CHPs, and boilers expansion planning: Alberta case study. In Proceedings of the 2015 IEEE Power & Energy Society General Meeting, Denver, CO, USA, 26–30 July 2015; pp. 1–5.
18. Abbasi, A.R.; Seifi, A.R. Simultaneous Integrated stochastic electrical and thermal energy expansion planning. *IET Gener. Transm. Distrib.* **2014**, *8*, 1017–1027. [[CrossRef](#)]
19. Abbasi, A.R.; Seifi, A.R. Unified electrical and thermal energy expansion planning with considering network reconfiguration. *IET Gener. Transm. Distrib.* **2015**, *9*, 592–601. [[CrossRef](#)]
20. Ceseña, E.A.M.; Capuder, T.; Mancarella, P. Flexible Distributed Multienergy Generation System Expansion Planning Under Uncertainty. *IEEE Trans. Smart Grid* **2016**, *7*, 348–357. [[CrossRef](#)]
21. Mojica, J.L.; Petersen, D.; Hansen, B.; Powell, K.M.; Hedengren, J.D. Optimal combined long-term facility design and short-term operational strategy for CHP capacity investments. *Energy* **2017**, *118*, 97–115. [[CrossRef](#)]
22. Dolatabadi, A.; Mohammadi-ivatloo, B.; Abapour, M.; Tohidi, S. Optimal Stochastic Design of Wind Integrated Energy Hub. *IEEE Trans. Ind. Informat.* **2017**, *13*, 2379–2388. [[CrossRef](#)]
23. Zhang, X.; Shahidehpour, M.; Alabdulwahab, A.; Abusorrah, A. Optimal Expansion Planning of Energy Hub With Multiple Energy Infrastructures. *IEEE Trans. Smart Grid* **2015**, *6*, 2302–2311. [[CrossRef](#)]
24. Domínguez-Muñoz, F.; Cejudo-López, J.M.; Carrillo-Andrés, A.; Gallardo-Salazar, M. Selection of typical demand days for CHP optimization. *Energy Build.* **2011**, *43*, 3036–3043. [[CrossRef](#)]
25. Zhou, X.; Guo, C.; Wang, Y.; Li, W. Optimal Expansion Co-Planning of Reconfigurable Electricity and Natural Gas Distribution Systems Incorporating Energy Hubs. *Energies* **2017**, *10*, 124. [[CrossRef](#)]
26. Nastasi, B.; Lo Basso, G. Power-to-Gas integration in the Transition towards Future Urban Energy Systems. *Int. J. Hydrog. Energy* **2017**, *42*, 23933–23951. [[CrossRef](#)]
27. Mathiesen, B.V.; Lund, H.; Connolly, D.; Wenzel, H.; Østergaard, P.A.; Möller, B.; Nielsen, S.; Ridjan, I.; Karnøe, P.; Sperling, K.; et al. Smart Energy Systems for coherent 100% renewable energy and transport solutions. *Appl. Energy* **2015**, *145* (Suppl. C), 139–154. [[CrossRef](#)]
28. Bakirtzis, G.A.; Biskas, P.N.; Chatziathanasiou, V. Generation Expansion Planning by MILP considering mid-term scheduling decisions. *Electr. Power Syst. Res.* **2012**, *86*, 98–112. [[CrossRef](#)]
29. Li, J.; Li, Z.; Liu, F.; Ye, H.; Zhang, X.; Mei, S.; Chang, N. Robust Coordinated Transmission and Generation Expansion Planning Considering Ramping Requirements and Construction Periods. *IEEE Trans. Power Syst.* **2017**, *PP*. [[CrossRef](#)]
30. Douglas, D.H.; Peucker, T.K. Algorithms for the reduction of the number of points required to represent a digitized line or its caricature. *Cartographica* **1973**, *10*, 112–122. [[CrossRef](#)]
31. Kolesnikov, A.; Fränti, P. Reduced-search dynamic programming for approximation of polygonal curves. *Pattern Recognit. Lett.* **2003**, *24*, 2243–2254. [[CrossRef](#)]
32. De Farias, I.; Zhao, M.; Zhao, H. A special ordered set approach for optimizing a discontinuous separable piecewise linear function. *Oper. Res. Lett.* **2008**, *36*, 234–238. [[CrossRef](#)]
33. Liu, Z.; Chen, Y.; Luo, Y.; Zhao, G.; Jin, X. Optimized Planning of Power Source Capacity in Microgrid, Considering Combinations of Energy Storage Devices. *Appl. Sci.* **2016**, *6*, 416. [[CrossRef](#)]
34. Park, E.; Kwon, S.J. Solutions for optimizing renewable power generation systems at Kyung-Hee University's Global Campus, South Korea. *Renew. Sustain. Energy Rev.* **2016**, *58*, 439–449. [[CrossRef](#)]
35. Korea-District-Heating-Cooperation (KDHC). Heat and Electricity Business Status. Available online: [http://www.kdhc.co.kr/content.do?sgrp=\\$23&siteCmsCd=CM3655&topCmsCd=CM3715&cmsCd=CM4487&pnum=10&cnum=81](http://www.kdhc.co.kr/content.do?sgrp=$23&siteCmsCd=CM3655&topCmsCd=CM3715&cmsCd=CM4487&pnum=10&cnum=81) (accessed on 20 July 2017).

36. Korea Power Exchange (KPX). Load Forecast. Available online: <http://www.kpx.or.kr/www/contents.do?key=223> (accessed on 20 July 2017).
37. Korea Farming and Fishing Village Construction. The Power Plant Generated Energy Present Condition for Photovoltaic Power Plants in Yeongam. Available online: <http://www.data.go.kr/dataset/15005796/fileData.do> (accessed on 23 July 2017).
38. Lazard. Levelized Cost of Energy Analysis. Available online: <http://www.lazard.com/perspective/levelized-cost-of-energy-analysis-100/> (accessed on 24 July 2017).



© 2017 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<http://creativecommons.org/licenses/by/4.0/>).

Copyright of Energies (19961073) is the property of MDPI Publishing and its content may not be copied or emailed to multiple sites or posted to a listserv without the copyright holder's express written permission. However, users may print, download, or email articles for individual use.